

# 30 day Alarm Activation Report

Monitored Fire Alarm Systems which have had 3 or more False Alerts in the last 30 days

<i>Alarm</i>	<i>Job No</i>	<i>Fault</i>	<i>Action</i>
Fire Detection and Alarm System BS5839 Pt 1			
0009	Incident Test Fire Alarm 1		
URN = FIRE		Activations = 3	
01/03/20 06:07	13	F02 FA - Technical	C02 REPAIRED
15/03/20 06:08	14	F02 FA - Technical	C02 REPAIRED
26/03/20 06:08	15	F02 FA - Technical	C06 REMOVED