

30 day Alarm Activation Report

Intruder Alarms which have had 3 or more False Alerts in the last 30 days

<i>Alarm</i>	<i>Job No</i>	<i>Fault</i>	<i>Action</i>
Intruder & Hold Up Alarm: PD 6662 & DD243			
0004	Incident Test - Intruder 1		
URN = 1		Activations = 3	
10/03/20 05:59	4	C01 FAULTY CONTROL UNIT	C01 REPLACEMENT
12/03/20 06:00	5	C01 FAULTY CONTROL UNIT	C01 REPLACEMENT
28/03/20 06:00	6	C02 FAULTY PIR	C04 RESET AND TESTED

Intruder Alarm:DD243 & BS4737 Pt 1, 3 & 4

0006	Incident Test - Intruder 2		
URN = 222		Activations = 3	
01/03/20 06:03	7	C03 FAULTY MICROWAVE	C07 RESITED
04/03/20 06:04	8	C03 FAULTY MICROWAVE	C02 REPAIRED
14/03/20 06:04	9	C03 FAULTY MICROWAVE	C01 REPLACEMENT